

WINDOW - VARIES BY PROJECT

SEAL

SECONDARY APPLICATION OF AIR & MOISTURE BARRIER TO BE INSTALLED AS SHOWN (AFTER WALL SYSTEM IS IN PLACE)

PREFINISHED, FRY SPRINGLOK 2-PIECE "MASONRY REGLET MA" W/ 4" LEG (OR APPROVED EQUAL) TO BE RUN BENEATH THE WINDOW SYSTEM - SET IN (2) CONT. BEADS OF SEALANT

TERMINATION BAR AT TOP OF SPM FLASHING MEMBRANE - FASTEN AT 8" O.C. - PROVIDE COMPATIBLE SEALANT BEHIND MEMBRANE AND OVER TOP OF TERMINATION BAR - FASTENER LENGTH AS REQ'D. FASTEN TO WALL / FRAMING

WALL - TYPE VARIES BY PROJECT

SINGLE PLY ROOFING SYSTEM - VARIES PER PROJECT

VAPOR RETARDER AS REQ'D.

DECK AS OCCURS - VARIES PER PROJECT

SEAL AROUND ENTIRE PERIMETER OF FRAME (BOTH SIDES)

WINDOW SILL AS OCCURS

"Z" GIRT OR OTHER SOLID SUBSTRATE FOR ATTACHMENT OF TERM BAR TO WALL

PRIMED COVER BOARD - RUN FULL HEIGHT UP TO WINDOW SILL

SHEATHING / DRAINAGE PLANE AS OCCURS

AIR & MOISTURE BARRIER - RUN INTO WINDOW OPENING

DEPTH AS REQ'D TO MATCH EXTERIOR CLADDING / RAIN-SCREEN ABOVE

MINERAL WOOL INSULATION BOARD (OR OTHER INSULATION AS OCCURS) - MUST RUN FULL HEIGHT UP TO WINDOW SILL

1' - 0" MIN.

8" MIN.

VERIFY

WINDOW SILL @ ROOF (RAIN SCREEN / EXTERIOR INSULATION)

WINDOW - VARIES BY PROJECT

SEAL

PREFINISHED, FRY SPRINGLOK 2-PIECE "MASONRY REGLET MA" W/ 4" LEG (OR APPROVED EQUAL) TO BE RUN BENEATH THE WINDOW SYSTEM - SET IN (2) CONT. BEADS OF SEALANT

TERMINATION BAR AT TOP OF SPM FLASHING MEMBRANE - PROVIDE COMPATIBLE SEALANT BEHIND MEMBRANE AND OVER TOP OF TERMINATION BAR - FASTENER LENGTH AS REQ'D. FASTEN TO WALL / FRAMING

WALL - TYPE VARIES BY PROJECT

SINGLE PLY ROOFING SYSTEM - VARIES PER PROJECT

AIR & MOISTURE BARRIER

VAPOR RETARDER AS REQ'D.

DECK AS OCCURS - VARIES PER PROJECT

SEAL AROUND ENTIRE PERIMETER OF FRAME (BOTH SIDES)

WINDOW SILL AS OCCURS

1' - 0" MIN.

8" MIN.

WINDOW SILL @ ROOF (INTERIOR INSULATION)