



**PLAN VIEW OF STEEL PLATE**

12"x12"x1/4" STEEL PLATE - WELD PIPE TO PLATE - ATTACH PLATE TO DECK WITH (12) #14 STS (OR APPROPRIATE FASTENERS FOR DECK TYPE AS DIRECTED BY A STRUCTURAL ENGINEER)

CAPPED, 2" DIA. x 3/16" STEEL PIPE (GALVANIZED) - WELDED TO STEEL BASE PLATE - COORDINATE LOCATION AND HEIGHT WITH OWNER AND DISH SUPPLIER AS REQ'D. - NOTE: SEAL ANY HOLES OR OTHER PENETRATIONS USED FOR THE GALVANIZING PROCESS

PRE-MOLDED SPM PIPE FLASHING

RIGID INSULATION - VARIES BY PROJECT

ROOF DECK VARIES BY PROJECT

2"

CONT. BEAD OF APPROVED SEALANT

AS REQ'D - COORD. W/ EQUIPMENT REQUIREMENTS

STAINLESS STEEL CLAMPING RING

FIELD FABRICATED METAL HOOD

FASTENER

2" MIN. WELDED SPLICE

NOTE THAT PITCH POCKETS ARE NOT AN ACCEPTABLE METHOD OF WATER-PROOFING BASE OF PIPES